

The modes of water supply to be adopted are as follows:

Height of Highest Fittings (Above Mean Sea Level)	Method of Supply
i) Up to 25 m	Direct.
ii) Higher than 25 m but up to *37 m	Indirect supply through high level storage tanks.
iii) Higher than 37 m	Indirect supply through low level tank with pumping to high level storage tanks.
(* Refers to height of inlet pipe to high level storage tanks.)	